


5. Place three AA batteries in the device.




6. Assemble the device and screw it back together.

7. Status, colour and behaviour of the diode (if the device is properly connected):


- Device is working correctly (power and memory) - single GREEN flash
- Device is working incorrectly (power and memory) - single RED flash
- Connecting to LoRaWAN - flashing BLUE
- LoRaWAN frame sent - single WHITE flash
- Confirmation from the server after receiving the frame - single WHITE flash
- Frame failed to confirm within specified timeout - single RED flash
- LoRaWAN Disconnected - flashing BLUE
- Connecting to BLE - flashing BLUE




1. Unscrew the device: remove 4 screws from the enclosure.



2. Unscrew the cable gland and remove the cap.



3. Pass the pulse counting cable through the cable gland.



4. Press the spring contact in the DI connector and insert the pulse counting cable. Tighten the cable gland to immobilize the sensor cable and maintain tightness.

